

IAPMO RESEARCH AND TESTING, INC.

4755 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body in which its product certification system includes inspection and testing of samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and/or warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued to:

TOPPEN HEALTH

675 HICKMAN CIRCLE
SANFORD, FL 32771

Product:

Drinking Water Treatment Unit - Aesthetic Effects

Products are certified to the following standard(s):

NSF/ANSI 42-2021

File Number: WP-17211

Effective Date: January 2025

Revised Date: January, 30 2025

Void After Date: January 2030*


Chairman, Product Certification Committee




Chief Technical Service Officer

* This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: TOPPEN HEALTH

File Number: WP-17211

Product: Drinking Water Treatment Unit - Aesthetic Effects

Effective Date: January 2025

Revised Date: January, 30 2025

Void After: January 2030

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

Product shall bear: The certified company name. The model number or trade designation. The appropriate certification mark. Product markings may be permanently fixed on the system or may be included as part of product literature or packaging.


Characteristics:

Point-of-use and point-of-entry systems intended to reduce substances affecting the aesthetic quality of the water or to add chemicals for scale control, or both. Certification demonstrates that all materials safety and structural integrity (as applicable) requirements have been met. To be installed in accordance with the manufacturer's installation instructions and the requirements of the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: TOPPEN HEALTH

File Number: WP-17211

Product: Drinking Water Treatment Unit - Aesthetic Effects

Effective Date: January 2025

Revised Date: January 30, 2025

Void After Date: January 2030

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Product Type	Point-of-Entry			
Model Number	Replacement Component	Flow Rate (GPM)	Capacity (Gallons)	Reduction Claims
50101-01	RA5775508, PAC2.5-10AG50E, 32-250-10	4.00	6,000	Chlorine, Taste & Odor, Particulate Class I
50202-01	RA5775526, PAC2.5-20AG50E, 32-250-20	8.00	12,000	Chlorine, Taste & Odor, Particulate Class I

Product Type	Squeeze Bottle			
Model Number	Replacement Component	Flow Rate (GPM)	Capacity (Gallons)	Reduction Claims
ULTRAWB	51001-01	0.211	25	Chlorine, Taste & Odor

Product Type	Point-of-Use			
Model Number	Replacement Component	Flow Rate (GPM)	Reduction Claims	
50601-01	50401-01	2.20	Particulate Class I	

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: TOPPEN HEALTH

File Number: WP-17211

Product: Drinking Water Treatment Unit - Aesthetic Effects

Effective Date: January 2025

Revised Date: January 30, 2025

Void After Date: January 2030

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org